

CERTIFICATE OF COMPLIANCE

Certificate Number 20190619-E498922
Report Reference E498922-20190616
Issue Date 2019-JUNE-19

Issued to: Apar Industries Ltd.
Unit: (Uniflex Cables)
Khata No. 1932, Survey No. 82/2P1
Khatalwada, Manekpur Road, Taluka -Umbergaon
District Valsad Gujarat 396120 INDIA

This certificate confirms that representative samples of THERMOSET-INSULATED WIRE
Type RW75 rated 600V

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 44 & CSA C22.2 NO. 38-18, Standard for Thermoset-Insulated Wires and Cables

Additional Information: See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

